

FIRE SAFETY CAERTIFICATE

No.MBMC/Fire/206/2026-27

DATE: 04/05/2026

Certified that the Ess VeePee Management Consultants Pvt.Ltd. at Survey No. (Old) 369/15,16, 382/1,2,4 (New) 69/15,16, 65/1,2,4 Goddev, Opp. Vardhaman Fantasy, Mira Road (E). Taluka District Thane (address) comprised of Ground + 4 upper floor in Building-B, and Ground + 7th upper floor in Building-C, and occupied by Sardar Vallabh bhai Patel Vidyalaya (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on Date, 04/05/2026 (date of inspection) in the presence of Mrs. Rakesh Patel, Trustee, and that the building/premises is fit for occupancy up to classes up to classes (X/XII) with effect from Date, 04/05/2026 for a period of 01 year in accordance with rule and subject to compliance of specific conditions as appended:-

A) Wet Riser System

- a) Single Hydrant Valve-08 Nos.
- b) First Aid Hose Reel Set-08 Nos.
- c) Canvas Hose Pipe - 02 Nos.
- d) Branch Pipe- 02 Nos.
- e) Single Door Hose Box - 02 Nos.
- f) Fire Brigade Connection - 01 Nos.
- g) Booster Pump-1 Nos.
- h) Main Pump - 1 Nos.

B) Fire Extinguisher

- a) ABC powder Type (5 Kg) - 22 Nos.
- b) ABC powder Type (2 Kg)-3Nos.
- c) ABC powder Type (1 Kg)-1 Nos.
- d) ABC powder Type (6 Kg) -2 Nos.

C) Fire Alarm System

- a) Fire Alarm Panel-1 Nos.
- b) MCP Hooter - 8 Nos.

Issued on Date 04/05/2026 (date of issue) at Mira- Bhayandar, Mira-Road (East) (place) by *Strike out whichever is not applicable.

Signature With Seal:-



Name & Address: **Dr. PRAKASH SHANKAR BORADE**
A. CHIEF FIRE OFFICER

FIRE & EMERGENCY SERVICES
MIRA-BHAYANDAR MUNICIPAL CORPORATION

